

FORT MYERS FIRE DEPARTMENT

FIRE PREVENTION BUREAU

2033 Jackson Street
Fort Myers, FL 33901
TEL: 239.321.7350
FAX: 239.344.5913
www.fortmyersfire.com

GENERAL REQUIREMENTS FOR SUBMISSION OF OTHER TRANSMISSION TECHNOLOGIES FIRE ALARM SYSTEM MONITORING

Please provide the following information for expediting your application

- 1) Provide specification sheets for all components, including wiring from FACP to the communicator. Also, indicate all hardware being removed.
- 2) Provide a copy of the installation manual, one for the office and one for the job site.
- 3) Provide information on FACP existing or new, indicate if intelligent or zone, if zoned provide proper detail on how the water flow will be monitored independent from a general alarm.
- 4) Provide a specific detail on how the FACP is connected to the communicator.
- 5) Provide information on where FACP and communicator are located, outside in a closet, approved air condition enclosure, or inside the building.
- 6) Note: If you are taking over monitoring of the system you shall provide, the sequence of operation, a copy of the contract, a contact list including the Lee County dispatch number (337-2000), and the UL certificate of compliance for the monitoring company.